

Usage analysis Church and Halls					Heating period: 28.9.2014 - 25.4.2015			7 months			
year	week	occupied hours			overlap hours	heating hours			lighting hours		
		Church	Upper hall	Lower hall	UH/LH	Church	Upper hall	Lower hall	Church	Upper hall	Lower hall
2014	30	16	15.5	23.5	9	0	168	168	5	2	3.5
2014	31	17.5	13.5	20	11	0	168	168	1.5	0	0.5
2014	32	13.5	16	26.5	7	0	168	168	4	2.5	7
2014	33	17.5	19	26	11	0	168	168	4	0.5	6
2014	34	17.5	18.5	22.5	9	0	168	168	4	3	4.5
2014	35	17	17	19	8.5	0	168	168	4	2	4.5
2014	36	22	35.5	31	19.5	0	168	168	6.5	14	8
2014	37	31	26.5	36	20.5	0	168	168	10	5	14
2014	38	19.5	25	36.5	19	0	168	168	8.5	9.5	16
2014	39	15.5	22	26.5	18.5	0	168	168	6.5	3.5	9
2014	40	16.5	22	22.5	15	30.5	168	168	8.5	8.5	11
2014	41	15.5	27	31	17	29.5	168	168	7.5	12.5	14.5
2014	42	16.5	24.5	73	15.5	29.5	168	168	8	11.5	14
2014	43	17	30.5	35	22.5	30.5	168	168	9	9	16
2014	44	28.5	25	26.5	18.5	43	168	168	11	13.5	11
2014	45	21.5	33	24	14	36.5	168	168	14	23.5	15
2014	46	21.5	31	33	18	32.5	168	168	11.5	17	22
2014	47	38.5	48.5	53	28.5	56	168	168	21	20.5	26
2014	48	21	28	22.5	13	32.5	168	168	9.5	16	14
2014	49	20.5	31	24.5	12.5	31.5	168	168	10	17	15.5
2014	50	23	29.5	35	19.5	36.5	168	168	13	17	19.5
2014	51	15	19.5	23	10	25	168	168	8	9	13.5
2014	52	22.5	22	27.5	18	36	168	168	15	15.5	16.5

2015	1	12.5	12	18	9	22.5	168	168	9.5	5.5	11.5
2015	2	16.5	20.5	23	9.5	32.5	168	168	8.5	9	12.5
2015	3	24	28	30	19.5	42	168	168	9.5	11.5	10.5
2015	4	16.5	34.5	34.5	21	30.5	168	168	10.5	17	13
2015	5	17.5	19.5	24	10.5	31.5	168	168	9.5	9	9.5
2015	6	24.5	34.5	30.5	20	42.5	168	168	11	15	11.5
2015	7	21	21.5	37	14.5	37.5	168	168	13	9	18.5
2015	8	15.5	34.5	35	23	31.5	168	168	8.5	15.5	17.5
2015	9	16.5	24	29	17	30.5	168	168	9.5	10	9.5
2015	10	17.5	34.5	27	14.5	31.5	168	168	8.5	17.5	13
2015	11	16.5	40.5	40	28	30.5	168	168	8.5	19	19
2015	12	18.5	24	27.5	14	35.5	168	168	8	10.5	13.5
2015	13	18.5	31.5	24	14.5	32.5	168	168	10.5	16.5	13
2015	14	14.5	31	36	22.5	28.5	168	168	3.5	12	10.5
2015	15	13	19.5	23	10.5	23	168	168	5.5	4	7
2015	16	9	20.5	32	14.5	17	168	168	4	7	9
2015	17	16.5	24.5	26.5	13	35.5	168	168	5	6.5	9
2015	18	18	23	30	15.5	0	168	168	5	5.5	9
2015	19	16	34.5	26.5	16.5	0	168	168	2.5	6	5
2015	20	17	28.5	26	13.5	0	168	168	2.5	4.5	5
2015	21	16	18.5	26	11.5	0	168	168	2.5	0.5	3
2015	22	16.5	33	29.5	19.5	0	168	168	2.5	5	3
2015	23	16.5	33.5	35.5	24.5	0	168	168	1.5	2.5	2
2015	24	20.5	22	23.5	13.5	0	168	168	3	1.5	2
2015	25	27	28	37.5	26	0	168	168	1	0	2
2015	26	16.5	26.5	29.5	18	0	168	168	1	0	2
2015	27	16.5	20.5	23	12	0	168	168	1	2	2
2015	28	14	23.5	23	12	0	168	168	1	0	2
2015	29	14.5	18.5	23	12	0	48	48	1	0	2
Total (h	52	962.00	1345.00	1528.00	825.00	984.50	8616.00	8616.00	367.50	454.50	528.50
Total nhp (h)		396.00	518.50	600.50	327.50	0.00	3576.00	3576.00	78.50	69.50	112.00
Total hp (h)		566.00	826.50	927.50	497.50	984.50	5040.00	5040.00	289.00	385.00	416.50